

**MEDIA, ENERGY AND SERVICES REQUIREMENTS  
FOR AMREST BRANDS**

Subject			KFC		BK		SBUX		
			Drive Thru (DT)	In Line (IL)	Drive Thru (DT)	In Line (IL)	Core	Signature	
Site's area	Optimum with social and storage base		n/a	400 m <sup>2</sup>	n/a	400 m <sup>2</sup>	150 m <sup>2</sup>	220 m <sup>2</sup>	
	Minimum with social and storage base		n/a	300 m <sup>2</sup>	n/a	300 m <sup>2</sup>	120 m <sup>2</sup>	150 m <sup>2</sup>	
	Optimum without social and storage base		n/a	n/a	n/a	n/a	110 m <sup>2</sup>	n/a	
	Minimum without social and storage base		n/a	n/a	n/a	n/a	90 m <sup>2</sup>	n/a	
	Optimum with drive and car park		1600 m <sup>2</sup>	n/a	1600 m <sup>2</sup>	n/a	n/a	n/a	
	Minimum with drive and car park		1300 m <sup>2</sup>	n/a	1300 m <sup>2</sup>	n/a	n/a	n/a	
	Optimum with drive and without car park		1100 m <sup>2</sup>	n/a	1100 m <sup>2</sup>	n/a	n/a	n/a	
	Minimum with drive and without car park		900 m <sup>2</sup>	n/a	900 m <sup>2</sup>	n/a	n/a	n/a	
	Optimum without drive and without car park		700 m <sup>2</sup>	n/a	700 m <sup>2</sup>	n/a	n/a	n/a	
	Minimum without drive and without car park		500 m <sup>2</sup>	n/a	500 m <sup>2</sup>	n/a	n/a	n/a	
Electricity for technological units	If natural gas available	Optimum	Instaled power	84 kW	84 kW	85 kW	85 kW	145 kW	145 kW
			Needed power	70 kW	70 kW	70 kW	70 kW	100 kW	100 kW
		Minimum	Instaled power	84 kW	84 kW	85 kW	85 kW	145 kW	145 kW
	If gas not available	Optimum	Instaled power	191 kW	191 kW	195 kW	195 kW	201 kW	201 kW
			Needed power	132 kW	132 kW	137 kW	137 kW	140 kW	140 kW
		Minimum	Instaled power	191 kW	191 kW	195 kW	195 kW	201 kW	201 kW
		Needed power	125 kW	125 kW	127 kW	127 kW	130 kW	130 kW	
Electricity for HVAC	Heating power	BOH	Optimum	50 kW	50 kW	50 kW	50 kW	50 kW	50 kW
			Minimum	30 kW	30 kW	30 kW	30 kW	30 kW	30 kW
		FOH	Optimum	80 W / m <sup>2</sup>	80 W / m <sup>2</sup>	80 W / m <sup>2</sup>	80 W / m <sup>2</sup>	80 W / m <sup>2</sup>	80 W / m <sup>2</sup>
			Minimum	60 W / m <sup>2</sup>	60 W / m <sup>2</sup>	60 W / m <sup>2</sup>	60 W / m <sup>2</sup>	60 W / m <sup>2</sup>	60 W / m <sup>2</sup>
	Cooling power	BOH	Optimum	60 kW	60 kW	60 kW	60 kW	50 kW	50 kW
			Minimum	45 kW	45 kW	45 kW	45 kW	40 kW	40 kW
		FOH	Optimum	120 W / m <sup>2</sup>	120 W / m <sup>2</sup>	120 W / m <sup>2</sup>	120 W / m <sup>2</sup>	120 W / m <sup>2</sup>	120 W / m <sup>2</sup>
			Minimum	100 W / m <sup>2</sup>	100 W / m <sup>2</sup>	100 W / m <sup>2</sup>	100 W / m <sup>2</sup>	100 W / m <sup>2</sup>	100 W / m <sup>2</sup>
Natural gas	For technological process (fryers, oven)	Optimum		12 m <sup>3</sup> /h	12 m <sup>3</sup> /h	12 m <sup>3</sup> /h	12 m <sup>3</sup> /h	n/a	n/a
		Minimum		10 m <sup>3</sup> /h	10 m <sup>3</sup> /h	10 m <sup>3</sup> /h	10 m <sup>3</sup> /h	n/a	n/a
	For heating	BOH	Optimum	9 m <sup>3</sup> /h	9 m <sup>3</sup> /h	9 m <sup>3</sup> /h	9 m <sup>3</sup> /h	n/a	n/a
			Minimum	8 m <sup>3</sup> /h	8 m <sup>3</sup> /h	8 m <sup>3</sup> /h	8 m <sup>3</sup> /h	n/a	n/a
Water	cold	Optimum daily demand		8500 l	8500 l	8500 l	8500 l	4000 l	4000 l
		Maximum daily demand		10000 l	10000 l	10000 l	10000 l	6000 l	6000 l
		Maximum hourly demand		2500 l	2500 l	2500 l	2500 l	2500 l	2500 l
	warm	Maximum second flow		1.7 l	1.7 l	1.7 l	1.7 l	1.2 l	1.2 l
		Optimum daily demand		4300 l	4300 l	4300 l	4300 l	20000 l	20000 l
		Maximum hourly demand		900 l	900 l	900 l	900 l	3000 l	3000 l
Sewage	Medium daily production		8500 l	8500 l	8500 l	8500 l	30000 l	30000 l	
	Maximum daily production		10000 l	10000 l	10000 l	10000 l	35000 l	35000 l	
	Maximum hourly production		2500 l	2500 l	2500 l	2500 l	5000 l	5000 l	
	Maximum second flow		4 l	4 l	4 l	4 l	6 l	8 l	
HVAC (must include also country regulations)	Flow	HOH	Optimum	6500 m <sup>3</sup> /h	6500 m <sup>3</sup> /h	7500 m <sup>3</sup> /h	7500 m <sup>3</sup> /h	4000 m <sup>3</sup> /h	4500 m <sup>3</sup> /h
			Minimum	5500 m <sup>3</sup> /h	5500 m <sup>3</sup> /h	6500 m <sup>3</sup> /h	6500 m <sup>3</sup> /h	3000 m <sup>3</sup> /h	3500 m <sup>3</sup> /h
		FOH	Optimum	55 m <sup>3</sup> /h / m <sup>2</sup>	55 m <sup>3</sup> /h / m <sup>2</sup>	55 m <sup>3</sup> /h / m <sup>2</sup>	55 m <sup>3</sup> /h / m <sup>2</sup>	55 m <sup>3</sup> /h / m <sup>2</sup>	55 m <sup>3</sup> /h / m <sup>2</sup>
			Minimum	35 m <sup>3</sup> /h / m <sup>2</sup>	35 m <sup>3</sup> /h / m <sup>2</sup>	35 m <sup>3</sup> /h / m <sup>2</sup>	35 m <sup>3</sup> /h / m <sup>2</sup>	35 m <sup>3</sup> /h / m <sup>2</sup>	35 m <sup>3</sup> /h / m <sup>2</sup>
	Exhaust	HOH	Optimum	6500 m <sup>3</sup> /h	6500 m <sup>3</sup> /h	7500 m <sup>3</sup> /h	7500 m <sup>3</sup> /h	4000 m <sup>3</sup> /h	4500 m <sup>3</sup> /h
			Minimum	5500 m <sup>3</sup> /h	5500 m <sup>3</sup> /h	6500 m <sup>3</sup> /h	6500 m <sup>3</sup> /h	3000 m <sup>3</sup> /h	3500 m <sup>3</sup> /h
		FOH (per sqr m)	Optimum	50 m <sup>3</sup> /h / m <sup>2</sup>	50 m <sup>3</sup> /h / m <sup>2</sup>	50 m <sup>3</sup> /h / m <sup>2</sup>	50 m <sup>3</sup> /h / m <sup>2</sup>	50 m <sup>3</sup> /h / m <sup>2</sup>	50 m <sup>3</sup> /h / m <sup>2</sup>
			Minimum	30 m <sup>3</sup> /h / m <sup>2</sup>	30 m <sup>3</sup> /h / m <sup>2</sup>	30 m <sup>3</sup> /h / m <sup>2</sup>	30 m <sup>3</sup> /h / m <sup>2</sup>	30 m <sup>3</sup> /h / m <sup>2</sup>	30 m <sup>3</sup> /h / m <sup>2</sup>
	Heating power demand	HOH	Optimum	65 kW	65 kW	65 kW	65 kW	65 kW	40 kW
			Minimum	45 kW	45 kW	45 kW	45 kW	45 kW	30 kW
		FOH (per sqr m)	Optimum	350 W/m <sup>2</sup>	350 W/m <sup>2</sup>	350 W/m <sup>2</sup>	350 W/m <sup>2</sup>	350 W/m <sup>2</sup>	350 W/m <sup>2</sup>
			Minimum	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>
	Cooling power demand	HOH	Optimum	55 kW	55 kW	55 kW	55 kW	25 kW	25 kW
			Minimum	50 kW	50 kW	50 kW	50 kW	20 kW	20 kW
		FOH (per sqr m)	Optimum	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>	300 W/m <sup>2</sup>
			Minimum	250 W/m <sup>2</sup>	250 W/m <sup>2</sup>	250 W/m <sup>2</sup>	250 W/m <sup>2</sup>	250 W/m <sup>2</sup>	250 W/m <sup>2</sup>
	blowed air		range		16°C-21°C	16°C-21°C	16°C-21°C	16°C-21°C	16°C-21°C

IT – 1x metallic wire (minimum 3 pairs) – especially in malls

WI-FI - written agreement from LL (landlord) in lease contract with our providing free WI-FI from our leased space

Written agreement from LL in lease contract with our music production in our leased space